

Office of the Public Advocate

Your Trusted Source for Utility Information



Expanding the Grid: How Big and Who Pays?

Summit on Maine's Economy and Climate Change

May 19, 2023

William Harwood

Maine Public Advocate

Office of the Public Advocate

Your Trusted Source for Utility Information



Regulation

- Merchant transmission Lines – who's minding the store?
- FERC vs. PUC regulation?
- Northern Maine transmission line – regulated or unregulated?

Office of the Public Advocate

Your Trusted Source for Utility Information



PUC CPCN Cases

- Traditional standard – Will rates be lower if line is built than if line is not built?
- What about environmental and aesthetic benefits?
- Conditions to PUC Approval
 - How many and how broad?
 - Is paying for these conditions simply a cost of doing business in Maine?
 - How should they be counted toward whether approval is justified?

Office of the Public Advocate

Your Trusted Source for Utility Information



Non-wire Alternatives (NWAs)

Should utilities be allowed to own and operate NWAs?

Expanding the Grid: What Functions, Flexibility, Costs?

Climate Work Summit on
Maine's Economy & Climate Change



David Littell

Chair, Climate Change Practice Group
Energy & Environmental Practice Group

Friday, May 19, 2023

Climate Action and Grid Needs

In Maine, we should make sure **every ratepayer* dollar is spent efficiently and effectively** to make the best investments for **customers*** to:

- Improve reliability and service,
- Build grid scale solar and wind,
- Support distributed resources,
- Improve efficiency and electrify, and
- Support Maine's future and economic growth.

*ratepayers must pay rates for service; customers receive benefits and choose how to spend their customer dollars

What Maine needs to make climate progress

- **Better planning** < scattershot
 - Long term integrated grid planning will help.
- **More cooperation** > contention
 - Governmental power is a huge diversion from climate progress.
- **A plan is directional**
 - Good plans are flexible.
 - Plans channel effort, spending, and training.

Factoids

Versant is working on 432 active projects to integrate 500+ megawatts of solar, wind.

Solar requests alone would generate more electricity than the Versant system needs.



Advanced Technology is expensive > use to pursue value


- Grid Value
- Customer Value
- Utility Value

Good policy aligns all three!

With technology and policy evolving, and processes changing – Maine will likely **remain in problem-solving mode.**

Advanced Energy Planning: New Approaches

- Transmission and distribution planning (traditional “supply side”) is understood.
- Demand-side management “DSM” is newer.
- Four DSM capabilities to exploit:
 - Shape load
 - Shift load
 - Shed load
 - Shimmy
- Pricing (rate design) is an effective approach to shape, shift, or shed load.
 - Versant **seasonal heating rates**
 - 13% customer adoption
 - Versant offers **time-variant EV charging rates**
 - Versant residential **customers can use both heating and EV rates** with different meters
 - No additional monthly minimum charge



Source: 2015 California Demand Response Potential Study, LBNL, November 2016

In Maine, we should make sure that **every ratepayer dollar is spent efficiently and effectively** to make the best investments for **customers** to:

- Improve reliability and service
- Build grid scale solar and wind
- Support distributed resources
- Improve efficiency and electrify; and
- Support Maine's future and economic growth.



Contact Information

David P. Little II, Esq.

+1207-228-7156

DLittleII@BernsteinShur.com




ClimateWork Maine

Richard Silkman, Ph.D.



Rethinking Electric Grid Design to Meet
Beneficial Electrification and Enhanced
Distributed Generation

A Portland Area Case Study



GridSolar, LLC
May 2020


**What is required for
Maine to achieve a
zero-carbon economy
through full beneficial
electrification and
maximum build-out of
distributed solar
generation**

<https://www.competitive-energy.com/rethinking-electrical-grid-design>



Portland Region – Electric Grid

Figure 2-4 Electrical Representation of the Distribution Circuits in the Portland Region



Modeling Energy Use:

- Building-by-Building – every single parcel in the region.
- Data – obtained from tax records in every community and from GIS mapping
- Circuit Data – from CMP

Table 3-1 Summary of Buildings in the Portland Area

| | Residential Buildings | Commercial Buildings | Industrial Buildings | Total |
|-------------------------------------|-----------------------|----------------------|----------------------|-------------|
| Number of Buildings | 73,000 | 6,167 | 1,003 | 80,170 |
| Total Square Footage | 209,782,673 | 67,793,059 | 18,802,851 | 296,378,583 |
| Average Square Footage per Building | 2,874 | 10,993 | 18,747 | 10,871 |

Current Energy Use – by Fuel and by Sector

Figure 3-1 Model Validation – by Month




Figure 3-3 Percent Energy Use by End-Use and Economic Sector






Figure 3-2 Model Validation by Hour of the Day



Beneficial Electrification

Table 4-1 Summary – Electricity Use by End-Use Sector Under Beneficial Electrification


| Load Type | Total Loads (MWh) | Maximum Demand (MW) | Capacity Factor % |
|-------------------------|-------------------|---------------------|-------------------|
| Current Electricity Use | 1,680,233 | 271 | 71% |
| Total Heating | 1,140,843 | 738 | 18% |
| Residential AC | 110,542 | 132 | 10% |
| Total Process | 583,248 | 123 | 54% |
| Total EV Charging | 613,343 | 145 | 48% |
| Total Loads | 4,128,208 | 1,086 | 43% |

Note: Demand levels shown are for each Load Type, respectively.
Demand levels for Total Loads are the coincident demands across all load types.

Overall load factor decreases markedly due to conversion of heating systems to electricity

**Electricity use - 246% higher
Peak Demand - 400% higher**

Figure 4-6 Hourly Electricity Use by End-Use Sector Under Beneficial Electrification



Maximum Build-out of Rooftop Solar in Region

Install Rooftop Solar on Every Building/Structure in the Portland Region – with full build-out achieved in 2050:

Capacity: 1,011 MW

Energy: 1,590,280 MWh

Coverage: 27% of all rooftop surface

39% of Total Electricity Use in the Region by 2050

Table 5-1 Installed Solar PV Generation – Portland Area

| | | 2020 | 2030 | 2040 | 2050 |
|------------------------------|--------|-------------|-------------|-------------|-------------|
| Residential | | | | | |
| Pct. Of Bldgs with Solar PV | % | 0% | 1% | 33% | 100% |
| Total Bldg. Footprint | Sq.Ft. | 127,783,933 | 127,783,933 | 127,783,933 | 127,783,933 |
| Number of Solar Panels | No. | 0 | 19,415 | 582,463 | 1,765,038 |
| Maximum Hourly Generation | MW | 0.00 | 6.12 | 183.61 | 556.41 |
| Pct. Of Rooftop Covered | % | 0.00% | 0.28% | 8.47% | 25.68% |
| Annual Solar Generation | MWh | 0 | 10,691 | 320,736 | 971,929 |
| Commercial | | | | | |
| Pct. Of Bldgs with Solar PV | % | 0% | 1% | 33% | 100% |
| Total Bldg. Footprint | Sq.Ft. | 50,412,359 | 50,412,359 | 50,412,359 | 50,412,359 |
| Number of Solar Panels | No. | 0 | 8,547 | 256,403 | 776,978 |
| Maximum Hourly Generation | MW | 0.00 | 2.75 | 82.62 | 250.35 |
| Pct. Of Rooftop Covered | % | 0.00% | 0.32% | 9.46% | 28.65% |
| Annual Solar Generation | MWh | 0 | 5,027 | 150,812 | 457,005 |
| Industrial | | | | | |
| Pct. Of Bldgs with Solar PV | % | 0% | 1% | 33% | 100% |
| Total Bldg. Footprint | Sq.Ft. | 17,342,593 | 17,342,593 | 17,342,593 | 17,342,593 |
| Number of Solar Panels | No. | 0 | 2,932 | 87,961 | 266,548 |
| Maximum Hourly Generation | MW | 0.00 | 0.96 | 28.79 | 87.24 |
| Pct. Of Rooftop Covered | % | 0.00% | 0.31% | 9.43% | 28.57% |
| Annual Solar Generation | MWh | 0 | 1,775 | 53,244 | 161,347 |
| TOTAL - All Buildings | | | | | |
| Total Bldg. Footprint | Sq.Ft. | 195,538,885 | 195,538,885 | 195,538,885 | 195,538,885 |
| Number of Solar Panels | No. | 0 | 30,894 | 926,826 | 2,808,565 |
| Maximum Hourly Generation | MW | 0.00 | 9.83 | 295.02 | 894.00 |
| Pct. Of Rooftop Covered | % | 0.00% | 0.29% | 8.81% | 26.70% |
| Annual Solar Generation | MWh | 0 | 17,493 | 524,792 | 1,590,280 |

Energy Balances/Imbalances by Building

Table 6-1 Annual Building Energy Balances – 2050

| Building Type | Estimated Building Energy Balances - 2050 [Rooftop Solar PV Generation as a Percent of Building Energy Use] | | | | | |
|--------------------|--|--------|--------|--------|---------|--------|
| | <20% | 20-40% | 40-60% | 60-80% | 80-100% | >100% |
| Residential | | | | | | |
| No. of Bldgs. | 20,266 | 13,719 | 11,937 | 9,001 | 7,671 | 10,408 |
| Percent | 28% | 19% | 16% | 12% | 11% | 14% |
| Cum. Percent | 28% | 47% | 63% | 75% | 86% | 100% |
| Commercial | | | | | | |
| No. of Bldgs. | 1,542 | 1,314 | 2,028 | 957 | 249 | 77 |
| Percent | 25% | 21% | 33% | 16% | 4% | 1% |
| Cum. Percent | 25% | 46% | 79% | 95% | 99% | 100% |
| Industrial | | | | | | |
| No. of Bldgs. | 400 | 593 | 13 | 1 | 0 | 1 |
| Percent | 40% | 59% | 1% | 0% | 0% | 0% |
| Cum. Percent | 40% | 99% | 100% | 100% | 100% | 100% |

Distribution Grid – Reliability Issues

Figure 6-1 Distribution Circuit Peak Loads






Figure 6-2 Reverse Power Flows on Distribution Circuits



Virtually every circuit in the region is undersized to carry peak loads and will experience significant reverse power flows ...

Distribution Grid – Reliability Issues

Figure 6-4 Max. Loads by 34/12.5 kV Transformer – 2020 – 2050 as a Pct. of High Ratings




The same problem exists for transformer capacity at the region's substations – by 2040, most will be well-undersized to meet future peak loads.

We will need to see a complete redesign and rebuilding of the region's Distribution Grid.


Electricity Flow – Current Imbalances

Figure 6-6 Hourly Energy Balances for the Portland Area



With essentially no Distributed Generation today, all of the region's electricity is imported. Hour-by-hour variation, however, is relatively small due to high annual load factor of current end uses of electricity.

Electricity Flow – Current Imbalances



By 2050, the region's grid must be capable of importing 1,000 MW of power – and this is true regardless of how much distributed solar is installed.

Storage could help – but it must be seasonal storage. Diurnal storage provides very little relief.

Transmission Grid Upgrade Costs

Table 8-6 Summary – Estimated Cost of Transmission/Subtransmission Upgrades - 2050

| Estimated Transmission/Subtransmission Costs | | | Cost |
|--|-----|-------|--------------------------|
| | No. | Miles | (millions\$) |
| 345 kV System | | | |
| New 345 kV Substations | 3 | | \$318.12 |
| 345 kV Line - Overhead | | 66 | \$424.96 |
| 345 kV line - Undersea | | 18 | \$231.80 |
| Subtotal | | | <u>\$974.88</u> |
| 115 kV System | | | |
| New 115 kV Substations | 4 | | \$218.32 |
| 345 kV Line - Overhead | | 84 | \$293.49 |
| 345 kV line - Undersea | | 1 | \$8.42 |
| Subtotal | | | <u>\$520.23</u> |
| 34.5 kV System | | | |
| New 115 kV/34.5 kV Substations | 25 | | \$556.97 |
| 34.5 kV Line - Overhead | | 225 | \$492.05 |
| 34.5 kV line - Undersea | | 0 | \$0.00 |
| Subtotal | | | <u>\$1,049.03</u> |
| Total Transmission/Subtransmission | | | <u>\$2,544.13</u> |

The total costs for the transmission upgrades required to serve 2050 electrical loads in the Portland Region will be roughly \$2.5 billion in 2020\$.

The Distribution cost upgrades are on top of this amount.


Grid Upgrade – Land Requirements

Table 8-7 Land-Use Consequences of Electric Grid Build-Out

| | | Width (ft.) | Length (miles) | Area (acres) |
|---------------------------|------------|------------------------|---------------------------|-------------------------|
| Transmission Lines | | | | |
| | | 150 | 66 | 1,200 |
| | | 100 | 84 | 1,018 |
| | | 50 | 225 | 1,364 |
| | | | | <hr/> |
| | | | | 3,582 |
| Substations | | | | |
| | No. | Width (ft.) | Length (ft.) | Area (acres) |
| | 3 | 1,200 | 1,700 | 140 |
| | 4 | 450 | 450 | 19 |
| | 25 | 200 | 200 | 23 |
| | | | | <hr/> |
| | | | | 182 |
| | | | | <hr/> |
| Total Land Area | | | | 3,764 |

Most of the land requirements for the upgrades are for linear corridors.

To put this acreage in perspective, the I-295/I-95 corridor from Freeport to Scarborough takes up a little less than 1,000 acres.



THANK YOU



The \$10 Trillion Problem

Estimates from:

*Gupta et al, Spatial analysis of distribution grid capacity and costs to enable massive deployment of PV, electric mobility and electric heating, University of Geneva, and

1898 Company (Burnes and McDonnell), Doug Houseman, Internal research

The Challenge

Regulatory solutions are
happening too slowly

Why Now?

Rapid growth in DER and Electrification.

Who Cares?

DER and Electrification creates new
system dynamics

Why it matters?

need to speed the new solutions, or
decarbonization will fail

DYNAMIC  GRID

Slaying the Distribution Dragon




Systems Architecture

Apply 'present forward' + 'future back' systems thinking and analysis to evaluate grid expansion proposals so that the grid can function holistically.



Grid Architecture

Grid Architecture is critical for making key structural choices to enable a more intelligent, self-optimising power system for the 21st century



Operational Coordination

Operational Coordination requires interaction between both markets and control structures

Economists
“Get the market rules and prices right and everything will work fine”

✓ **Solution:**

An ensemble of both market and control features is required

Control Engineers
“Get the algorithms and standards right and everything will work fine”

